

COMMONWEALTH OF KENTUCKY

BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

PAUL F. HILPP, ROBERT P. BRADY,)
WILLIAM P. THOMPSON, BRIAN M.)
MATTINGLY, MR. & MRS. SAMUEL E. LEE)
III, RICHARD AND ANGELA MATTINGLY,)
JOSEPH R. HUGHES, CHARLES AND TERRY)
CAMPBELL, TIMOTHY GERALD EWING, ROBERT)
AND PATRICIA CLEMENTS, JOSEPH PAUL AND)
VICKIE BRADY, AND JAMES C. HANKS)

COMPLAINANTS)

VS.)

EAST KENTUCKY POWER COOPERATIVE, INC.)

DEFENDANT)

CASE NO. 95-087

O R D E R

IT IS ORDERED that East Kentucky Power Cooperative, Inc. ("East Kentucky") shall file the original and 12 copies of the following information with the Commission with a copy to all parties of record no later than 14 days after the date of this Order. East Kentucky shall furnish with each response the name of the witness who will be available to respond to questions concerning each item of information requested should a public hearing be scheduled.

1. Provide a list of Inter-County RECC's existing customers in the Marion County Industrial Park, their power requirements and the nature and size of facilities through which each is served.

2. What are the anticipated load requirements of Worthington Industries and Wallace Computers?

3. In its Answer, pages 2-3, East Kentucky identified the following alternatives to serve new customers in the Marion County Industrial Park:

a. Construct a 69/25 KV substation in the Marion County Industrial Park to be served by a 69 KV transmission line from the Loretto substation;

b. Construct a 69/25 KV substation at the existing Lebanon substation to be served from the Kentucky Utilities Company ("KU") transmission system; and

c. Construct a 69/25 KV substation in the Marion County Industrial Park to be served by a two mile 69 KV tap from KU's Lebanon City-Taylor County 69 KV transmission line.

For each alternative listed above, provide a detailed schedule of costs, load flow studies, a present worth revenue requirements analysis and a map delineating the existing facilities and those to be constructed.

4. Identify each alternative considered by East Kentucky but not listed above in Item No. 3. For each such alternative, provide the same information as requested in Item No. 3.

5. In light of the recent resolution of East Kentucky's challenge to the KU Interconnection Agreement, discuss the current feasibility of KU wheeling power to serve the additional load requirements in the Marion County Industrial Park.

6. Has East Kentucky determined the specific route for the proposed seven mile transmission line from the Loretto substation?

If yes, provide a detailed map showing the selected route. If not, state when a route will be selected.

7. Explain how the comments and concerns expressed by the public at a meeting in Lebanon, Kentucky, have been considered in routing the proposed seven mile transmission line from the Loretto substation.

Done at Frankfort, Kentucky, this 31st day of May, 1995.

PUBLIC SERVICE COMMISSION


For the Commission

ATTEST:


Executive Director